



1 SECOND FLOOR FIRE ALARM PLAN  
SCALE: 1/8" = 1'-0"

# SHEET NOTES

- 1 REFER TO LEGEND
- 2 REFER TO WIRING SCHEDULE THIS SHEET. SEE 1ST FLOOR PLAN FOR WIRING DIAGRAM
- 3 (E) BACK BOX FOR DOOR HOLDER WITH 3/4" C & PULLSTRING TO FACP GUTTER ON 1ST FLOOR.
- 4 (E) JUNCTION BOX FOR 120VAC POWER CONNECTION TO DOOR HOLDER DEVICE.
- 5 DOWN TO FIRE ALARM CONTROL PANEL ON 1ST FLOOR.
- 6 FIRE ALARM DEVICES, CONDUIT AND WIRE ARE IN ALTERNATE #3.

WIRING SCHEDULE			
DEVICE	WIRE		REMARKS
	LABEL	SIZE	
1	A	#14	
2	A, B	#14, #16	
3	C	#16	
4	D	#16	INSTALL IN ACCORDANCE W/ MANUFACTURER'S LISTING
5	F	#16	

- NOTES: 1 MINIMUM CONDUIT SIZE = 3/4" EMT  
2 EOL DEVICES SHALL BE INSTALLED BY UNIVERSITY IN MAIN FACP WHEN F.A. CIRCUITS ARE CONNECTED.  
3 CONDUIT ROUTING SHOWN IS SCHEMATIC ONLY. EXACT ROUTING SHALL BE FIELD-COORDINATED.

**GLUMAC**  
GLUMAC & ASSOCIATES, INC.  
CONSULTING ENGINEERS  
CORPORATE CENTER SUITE 200  
278 BATTERY STREET, SUITE 200  
SAN FRANCISCO, CALIFORNIA 94111  
(415) 398-7887 43W94,05A

WOODFORD/SLOAN  
ARCHITECTS  
539 BRYANT STREET  
SAN FRANCISCO, CA 94107  
(415) 466-8888

BUILDING 64  
OFFICE & LABORATORY RENOVATION  
2ND FLOOR  
FIRE ALARM PLAN  
UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY LABORATORY  
FACILITIES DEPARTMENT

DATE: 1/27/95  
DESIGNED BY: PAT  
CHECKED BY: M.S.  
DATE: 1/27/95  
E7.2  
4N64E039  
PROJECT NO. 120700